

No. FS/NOC/BLDG(O)/2013/1625  
GOVERNMENT OF MIZORAM  
FIRE & EMERGENCY SERVICES DEPARTMENT  
MIZORAM : AIZAWL

Dated Aizawl, the 20<sup>th</sup> Jan, 2021.

**NO OBJECTION CERTIFICATE (PROVISIONAL)**

Kendriya Vidyalaya School, Thuampui, Zemabawk has been inspected on 7.1.2021 in respect of implementation of Fire Prevention arrangement and the undersigned has no objection in its occupation/utilization for the institution subject to the installation of the following Fire Fighting arrangements as per the provision of Part IV of NCB, 2016 as mentioned below:

**1. Ground Floor :**

- (a) Fire Bucket with sand 8 Nos.  
(b) Biological Laboratory Room - CO2 Fire extinguishers 2 kg (2 nos.) and ABC/DCP, 4kg (3 nos.)  
(c) Chemistry Laboratory Room - CO2 Fire extinguishers 2 kg (2 nos.) and ABC/DCP, 4kg (7 nos.)  
(d) Language Room - CO2 Fire extinguishers 2 kg (1 no.)

**2. First Floor :**

- (a) Fire Extinguishers ABC/DCP, 4kg (1 no.)

**3. Second Floor :**

- (a) CO2 Fire extinguishers 2 kg (5 nos.) and ABC/DCP, 4kg (2 nos.)

4. Miniature Circuit Breaker to be installed at every floor.

This Provisional NOC is valid for 2 (two) years which may be renewed for another 2 (two) years on receipt of proper application indicating the reason for its renewal. Final NOC will be issued after satisfactory inspection report about the installation of the above Firefighting arrangements is received.



*(Signature)*  
(C. LALTHANMAWIA)

Director,  
Fire & Emergency Services,  
Mizoram, Aizawl.